

OFFICE OF THE MUNICIPAL COUNCIL GARIYABAND
DISTRICT - GARIYABAND (C.G.)

Email-nagarpalikagariyaband@gmail.com


No. 515 /MCO/W.T.C/2026-27

Gariyaband, Dated 19-08-2026


SAFE DRINKING WATER & SANITARY CONDITON CERTIFICATE

It is certified that an inspection team headed by Mrs. Sandhya Verma, Chief Municipal Officer from Office of the Municipal Council Gariyaband inspected the Angels Anglo High School, Behind Govt. PG College Gariyaband on 19-08-2026 and on the basis of water test report (Attached) bearing no. DL/PHED/GBN - 131 dated 17-09-2025 of District Water Testing Laboratory, Gariaband, certified that the Angels Anglo High School, Gariyaband has safe drinking water facilities for the student and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This certificate is valis till 16-09-2028


मुख्य नगरपालिका अधिकारी
Chief Municipal Officer
मुनिसिपाल-गरीयबन्द (म.म.)
Municipal-Gariyaband

To,
The Principal
Angels Anglo High School. Gariyaband



SCHOOL MANAGER
ANGELS ANGLO HIGH SCHOOL
GARIABAND (C.G.)


PRINCIPAL
ANGELS ANGLO HIGH SCHOOL
GARIABAND



TC- 13013

District Water Testing Laboratory

Public Health Engineering Department, Div. Gariyaband
Devbhog Main Road, Rawanbhatha, Keshodar Road Gariyaband (C.G.)
e-mail:- eegar-phe-cg@nic.in

Test Report (Drinking Water)

Report no. DL/PHED/GBD. - 131	ULR No. TC1301320250000131F	Group:- Drinking Water		
Senders name & address:- Principal Angles Anglo High School Gariyaband Dist-Gariyaband (C.G.)	Senders letter no./Date	0932/12.09.2025	Sampled by	Water Sample Collected by Assistant Engineer Gariyaband
	Sample collection date	12.09.2025	Sampling Plan & procedure	-
	DL receipt no.	131	DL Receipt date	12.09.2025
	Date of analysis started	13.09.2025	Date of analysis completed	15.09.2025

Sample Details

S.N.	Sample I.D.	District /Block	City / Village	Habitation	Location/Source ID./GPS Identification
1	131/1601/09/2025	Gariyaband	Gariyaband	Gariyaband	Angels Anglo High School Gariyaband
2	-	-	-	-	-
3	-	-	-	-	-
4	-	-	-	-	-
5	-	-	-	-	-
6	-	-	-	-	-

Details of parameters their test method units and specification as per IS/APHA

Details of parameters their test method units and specification as per IS/APHA												
S.N.	Parameters	Test method IS:3025/APHA 23rd ed.		Unit	As per IS-10500-2012 drinking water		Result Of S.No.					
		Method	Part no.		Accepta ble Limit	Permiss ible Limit	1	2	3	4	5	6
1	2	3	4	5	6	7	8	9	10	11	12	13
1	Turbidity (25°C)	APHA23rd ed.	2130 B : 2017	NTU	1	5	0.75	-	-	-	-	-
2	pH (25°C)	APHA23rd ed.	4500 B : 2017	PH scale	6.5-8.5	No Relaxation	6.93	-	-	-	-	-
3	Alkalinity as CaCO ₃	APHA23rd ed.	2320 B : 2017	mg/l.	200	600	97.95	-	-	-	-	-
4	Chloride as CL	APHA23rd ed.	4500 B : 2017	mg/l.	250	1000	37.16	-	-	-	-	-
5	Total Hardness as CaCO ₃	APHA23rd ed.	2340 C : 2017	mg/l.	200	600	97.02	-	-	-	-	-
6	Calcium as Ca ²⁺	APHA23rd ed.	3500 B : 2017	mg/l.	75	200	24.60	-	-	-	-	-
	Magnesium as Mg ²⁺	APHA23rd ed.	3500mg B : 2017	mg/l.	30	100	8.66	-	-	-	-	-
8	Colour	APHA23rd ed.	2120 Colour Method-B	Hazen	05	15	01	-	-	-	-	-
9	Taste	IS:3025	Part- 8 : 2017	-	Agreeable	Agreeable	Agreeable	-	-	-	-	-
10	Odour	IS:3025	Part- 5 : 2018	-	Agreeable	Agreeable	Agreeable	-	-	-	-	-
11	TDS	APHA23rd ed.	2540 C : 2017	mg/l.	500	2000	160.00	-	-	-	-	-

- The report should not be produced partly or full without approval signatory authority of legal purpose.
- It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible" limit in the absence of alternate source in column 7 above which the sources will have to be rejected.
- The results refer only to tested samples and parameters.
- Samples will be stored for a period of 10 days from date of issue of report.
- This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.
- The Laboratory does not give interpretation on Test result Passed / Failed.

Report Checked By

(Teerath Sahu)
(Teerath Sahu)

(Vani Sahu)
(Vani Sahu)
Authorized Signatory
(Quality Manager)

District Water Testing Laboratory

Public Health Engineering Department, Div. Gariyaband
Devbhog Main Road, Rawanbatha, Keshodar Road Gariyaband (C.G.)
e-mail: eegar-phe-cg@nic.in

Test Report (Drinking Water)

Report no. DL/PHED/GBD. - 131		Group: Drinking Water		
Senders name & address:- Principal Angles Anglo High School Gariyaband Dist-Gariyaband (C.G.)	Senders letter no./Date	0932/12.09.2025	Sampled by	Water Sample Collected by Assistant Engineer Gariyaband
	Sample collection date	12.09.2025	Sampling Plan & procedure	-
	DL receipt no.	131	DL Receipt date	12.09.2025
	Date of analysis started	13.09.2025	Date of analysis completed	15.09.2025

Sample Details


S.N.	Sample I.D.	District /Block	City / Village	Habitation	Location/Source ID/GPS Identification
1	131/1601/09/2025	Gariyaband	Gariyaband	Gariyaband	Angels Anglo High School Gariyaband
2	-	-	-	-	-
3	-	-	-	-	-
4	-	-	-	-	-
5	-	-	-	-	-
6	-	-	-	-	-

Details of parameters their test method units and specification as per IS/APHA

S.N.	Parameters	Test method IS:3025/APHA 23rd ed.		Unit	As per IS-10500-2012 drinking water		Result Of S.No.					
		Method	Part no.		Accepta ble Limit	Permissi ble Limit						
							1	2	3	4	5	6
1	2	3	4	5	6	7	8	9	10	11	12	13
12	Iron	APHA 23rd ed	3500 -Fe -B	mg/l.	0.3	1.0	-	-	-	-	-	-
13	Nitrates	APHA 23rd ed	4500-NO3 - B	mg/l.	45	No Relaxation	-	-	-	-	-	-
14	Fluoride	APHA 23rd ed	4500-F-- C	mg/l.	1.0	1.5	0.428	-	-	-	-	-
15	Residual Chlorine	-	-	mg/l.	0.2	1.0	-	-	-	-	-	-
16	Sulphate	IS:3025	Part- 24	mg/l.	200	400	-	-	-	-	-	-
17	Manganese	APHA23rd ed.	3500Mn-B	Mg/l.	0.1	0.3	-	-	-	-	-	-
18	Spe.Conductivity	IS:3025	Part- 14	µmho/cm	-	-	-	-	-	-	-	-
19	E.Coli	-	-	CFU/100ml	Nil	Nil	Nil	-	-	-	-	-

1. The report should not be produced partly or full without approval signatory authority of legal purpose.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible" limit in the absence of alternate source in column 7 above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters.
4. Samples will be stored for a period of 10 days from date of issue of report.
5. This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.
6. The Laboratory does not give interpretation on Test result Passed / Failed.

Report Checked By


(Teerath Sahu)

Issue no.131 Date :- 16/09/2025

Page no. 01/01

:End of Test Report :


Chemist
District Water Testing Laboratory
P.H.E.D. Gariyaband (C.G.)